

# 2023 Water Quality Report for CITY of BANGOR

Water Supply Serial Number: 0380 WSSN

This report covers the drinking water quality for the City of Bangor for the 2023 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2023. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Your water comes from wells 3,7,8, and 9 groundwater wells, each over 70 to 219 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is HIGHLY SUSCEPTIBLE.

There are significant sources of contamination which include old abandon wells, old fuel tanks, and old industrial sites in our water supply. We are making efforts to protect our sources by securing monies to continue to cap of old wells, clean up sites, and update / restart our wellhead protection program.

If you would like to know more about this report, please contact: City Manager Justin Weber 269-427-5831 or Steven Lowder Director / Operator 269-312-4298.

**Contaminants and their presence in water:** Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be

obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791).

**Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

**Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, can be naturally occurring or result from urban stormwater runoff, industrial or




- domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2023 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2023. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG)**: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL)**: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL)**: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG)**: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Treatment Technique (TT)**: A required process intended to reduce the level of a contaminant in drinking water.
- **N/A**: Not applicable
- **ND**: not detectable at testing limit
- **ppm**: parts per million or milligrams per liter
- **ppb**: parts per billion or micrograms per liter
- **ppt**: parts per trillion or nanograms per liter



In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

- pCi/l: picocuries per liter (a measure of radioactivity)
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- Level 1 Assessment: A study of the water supply to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.



1 Monitoring Data for Regulated Contaminants

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Arsenic (ppb)	10	0	6.4 ppb	5.7 to 6.4	2023	no	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.098 ppm	.011 to .098	2021	no	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Nitrate (ppm)	10	10	ND	ND	2023	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	.89 ppm	.17 to .89	2023	no	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium <sup>1</sup> (ppm)	N/A	N/A	14 ppm	8.5 to 14 ppm	2021	no	Erosion of natural deposits
TTHM Total Trihalomethanes (ppb)	80	N/A	ND	ND	2023	no	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	ND	ND	2023	no	Byproduct of drinking water disinfection
Chlorine <sup>2</sup> (ppm)	4	4	5.85 ppm	3.02 to 5.85	2023	no	Water additive used to control microbes
Alpha emitters (pCi/L)	15	0	2.25pCi/L	.546 to 2.25pCi/L	2022	no	Erosion of natural deposits
Combined radium (pCi/L)	5	0	.522 pCi/L	0 to .522 pCi/L	2022	no	Erosion of natural deposits
Total Coliform	TT	N/A	N/A	N/A	N/A	N/A	Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli note <sup>3</sup>	0	0	N/A	2023	no	Human and animal fecal waste
Fecal Indicator – E. coli at the source (positive samples)	TT	N/A	0	N/A	2023	no	Human and animal fecal waste

<sup>1</sup> Sodium is not a regulated contaminant.

<sup>2</sup> The chlorine “Level Detected” was calculated using a running annual average.

<sup>3</sup> *E. coli* MCL violation occurs if: (1) routine and repeat samples are total coliform-positive and either is *E. coli*-positive, or (2) the supply fails to take all required repeat samples following *E. coli*-positive routine sample, or (3) the supply fails to analyze total coliform-positive repeat sample for *E. coli*.

<sup>4</sup> Ninety (90) percent of the lead and copper samples collected were at or below the level reported for our water.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Bangor is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.



Per- and polyfluoroalkyl substances (PFAS)							
Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ppt)	370	N/A	123 ppt	113 to 123 ppt	2022	no	Discharge and waste from industrial facilities utilizing the Gen X chemical process
Perfluorobutane sulfonic acid (PFBS) (ppt)	420	N/A	< 2 ppt	< 2 ppt	2023	no	Discharge and waste from industrial facilities; stain-resistant treatments
Perfluorohexane sulfonic acid (PFHxS) (ppt)	51	N/A	< 2 ppt	< 2 ppt	2023	no	Firefighting foam; discharge and waste from industrial facilities
Perfluorohexanoic acid (PFHxA) (ppt)	400,000	N/A	< 2 ppt	< 2 ppt	2023	no	Firefighting foam; discharge and waste from industrial facilities
Perfluorononanoic acid (PFNA) (ppt)	6	N/A	< 2 ppt	< 2 ppt	2023	no	Discharge and waste from industrial facilities; breakdown of precursor compounds
Perfluorooctane sulfonic acid (PFOS) (ppt)	16	N/A	< 2 ppt	< 2 ppt	2023	no	Firefighting foam; discharge from electroplating facilities; discharge and waste from industrial facilities
Perfluorooctanoic acid (PFOA) (ppt)	8	N/A	< 2 ppt	< 2 ppt	2023	no	Discharge and waste from industrial facilities; stain-resistant treatments
Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your Water <sup>4</sup>	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	1 ppb	0 to 1 ppb	2023	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.096 ppm	0.0 to 0.4	2023	0	Corrosion of household plumbing systems; Erosion of natural deposits



**Information about lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Bangor is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Infants and children who drink water containing lead could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper more than the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Our water supply has 700 lead service lines and 250 service lines of unknown material out of a total of 1350 service lines with about 400 shut odd or disconnected at the main.

**Monitoring and Reporting to the Department of Environment, Great Lakes, and Energy (EGLE) Requirements:** The State of Michigan and the U.S. EPA require us to test our water on a regular basis to ensure its safety. We use Paw Paw Labs and Trace Labs for our testing and also South Haven City as a backup if needed. We met all the monitoring and reporting requirements for 2023.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at City Hall 257 West Monroe and Public Works 421 West Arlington Street. This report is also on the city's webpage. This report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. The council meets the first and third Monday's at 7 pm in the council chambers at 257 West Monroe Street. For more information about your water, or the contents of this report, contact Steven Lowder Operator at 269-312-4298. Our website [bangormi.org](http://www.epa.gov/safewater). For more information about safe drinking water, visit the U.S. EPA at <http://www.epa.gov/safewater>.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at Bangor City Hall 257 W. Monroe Street or Public Works 421 W. Arlington Street, also on our city website at [cityofbangormi.org](http://cityofbangormi.org). This report will be published in the Van Buren Reminder. Be advised this report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. The council meets on the first and third Mondays of the month at 7 pm at the council chambers on 257 W. Monroe Street. For more information on your water, or the contents of this report, contact Justin Weber, City Manager at 269-427-5831 or Steven Lowder, Operator, at 269-312-4298. For more information about safe drinking water, visit the U.S. EPA at <http://epa.gov/safewater>.